



Office No. 9, Aakashganga Society, Near ICICI ATM, Pimple Nilakh, Pune 411027.
Call: +91 9822757322, 020 27271660 | satyamfire11@gmail.com | www.satyamfire.in

FORM – B

Date: 19/3/2024

(See section 3 (3) and rule 4 (2))

Certificate by the Licensed Agency regarding the compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

I / We Further certify that these installations in the above mentioned Building are maintained good repair and efficient conditions during the period 1 Jan 2024 – 30 June 2024, as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006(Mah-III of 2007).The details of the inspection and maintenance of installation carried out by me/us are mentioned as below, herewith.

The details of the work and related activities which I or we have executed or performed are mentioned In the list appended herewith.

Location of Site or Premises

C.M.INTERNATIONAL SCHOOL,4/2a,BALEWADI,PUNE - 411045.

Place: - Pune

Date: - 19/3/2024

**Satyam Fire
S.No.67, House No205, Ganesh Nagar,
Pimple Nilakh,
Pune - 411027
License No.MFS-LA/RF-114/D-110**

[*Note - For each building a separate certificate in Form 'B' should be necessary]

Ignal Kaur
Principal



C M International School

MAHESH
NETAJI SATHE
Authorized Signatory



Office No. 9, Aakashganga Society, Near ICICI ATM, Pimple Nilakh, Pune 411027.
Call: +91 9822757322, 020 27271660 | satyamfire11@gmail.com | www.satyamfire.in

Date: 19/3/2024

Description of Building or Premises.
C.M.INTERNATIONAL SCHOOL,4/2a,BALEWADI,PUNE - 411045.

The details of the work and related activities which I or we have executed or performed are mentioned in the list appended herewith.

SR.NO	ITEMS	PARTICULARS	QTY.
1	FIRE PUMP	TERRACE BUSTER PUMP	01 NOS
2	EXTINGUISHERS	PORTABLE FIRE EXTINGUISHERS IS: 15683/2006 ABC 6KG.	10
3	SINGLE HYDRANT VALVE	PROVIDE AT VARIOUS LOCATION 63MM AS PER IS-5290.	05
4	HOSE BOX	PROVIDE AT VARIOUS LOCATION.AROUND THE BUILDING.	05
5	HOSE PIPE	PROVIDE AT VARIOUS LOCATION AS PER IS-636	05
6	BRANCH PIPE	PROVIDE AT VARIOUS LOCATION AS PER IS- 903	05
7	HOSE REEL	PROMINENT PLACES.PROVIDE AT STRATEGIC LOCATION. 30 MTR.19MM.IS884:1985	04
8	FIRE BRIGADE CONECTION	PROVIDE MAIN GATE	01
9	MANUALLY OPERATED FIRE ALARAM SYSTEMS	FACTORY SHED & OFFICE BUILDING.PROVIDE AT VARIOUS LOCATION	INSTALLED

Place: - Pune

Date: - 19/3/2024

Ignat Kaul

Principal

C M International School



Satyam Fire
S.No.67, House No.205, Ganesh Nagar,
Pimple Nilakh,
Pune 411027
License No. MFS-LA/RF-114/D-110

MAHESH
NETAJI SATHE
Authorized Signatory